

GENERAL NOTES:

- 1. REFER TO THE CITY OF CONCORD SPECIFICATIONS FOR ACCEPTABLE MANUFACTURES OF MATERIALS.
- 2. PROVIDE 12" BRASS NIPPLE PAST BOX
- 3. THE METER HOUSING SHALL BE MID STATE PLASTICS OR EQUAL;
 3/4-INCH BOX MSBCF 1118-12XL AND LID MSCBC-1118- RTR; AND
 1-INCH BOX MSBCF -1324-12XL AND LID MSCBC-1324- RTR. METER BOX RIM
 SHALL BE SET FLUSH WITH FINAL GRADE. THE WATER METER BOX ASSEMBLY SHALL
 NOT BE LOCATED WITHIN A ROAD, STREET, DRIVEWAY, SIDEWALK OR DRAINAGE FEATURE.
- 4. ALL APPURTENANCES FOR THE INSTALLATION OF THE WATER METER; THE METER, BRASS GROUND LOCKABLE METER CUTOFF, GASKETS, AND EXPANSION CONNECTION; SHALL BE INSTALLED BY THE CITY OF CONCORD, IF CONNECTION IS TO AN EXISTING MAIN.
- 5. THE BASE OF THE METER BOX MUST HAVE AT LEAST 6-INCHES TO 8-INCHES OF #57 WASHED STONE.



